

OBC DUCT SIZING - PRINCIPAL FAN DUCT

for design and performance of residential ventilation systems to OBC 2012 - 9.32

1. Design Condition	2. Equipment															
Location: _____ # of Bedrooms: _____ Design Airflow: _____ cfm ESP: _____ " w.c. Note: external static pressure of the fan needs to be in accordance with OBC 9.32.3.9.(3)	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;"></td> <td style="width: 33%; text-align: center;">Coupled to Forced Air</td> <td style="width: 33%; text-align: center;">Not Coupled</td> </tr> <tr> <td style="text-align: center;">HRV/ERV</td> <td style="text-align: center;">Exhaust Fan</td> <td style="text-align: center;">Inline Fan</td> </tr> <tr> <td>Make: _____</td> <td colspan="2">_____</td> </tr> <tr> <td>Model: _____</td> <td colspan="2">_____</td> </tr> <tr> <td>Equipment Rated Airflow: _____ cfm @ _____ " w.c.</td> <td colspan="2">_____</td> </tr> </table>		Coupled to Forced Air	Not Coupled	HRV/ERV	Exhaust Fan	Inline Fan	Make: _____	_____		Model: _____	_____		Equipment Rated Airflow: _____ cfm @ _____ " w.c.	_____	
	Coupled to Forced Air	Not Coupled														
HRV/ERV	Exhaust Fan	Inline Fan														
Make: _____	_____															
Model: _____	_____															
Equipment Rated Airflow: _____ cfm @ _____ " w.c.	_____															

3. Duct Sizing using Table 9.32.3.4.B	Longest Total Duct Length from Grille to Outdoor Hood: _____ (39' max)				
# of elbows used: _____ (4 max)	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; text-align: center;">Trunk</td> <td style="width: 50%; text-align: center;">Branch</td> </tr> <tr> <td style="text-align: center;">Smooth Flex</td> <td style="text-align: center;">Smooth Flex</td> </tr> </table>	Trunk	Branch	Smooth Flex	Smooth Flex
Trunk	Branch				
Smooth Flex	Smooth Flex				
Min. Required Diameter for Exhaust Duct: _____	(see Table 9.32.3.4.B)				
Min. Required Dia. for Supply Duct from Outdoor Hood to Return if applicable: _____	(see Table 9.32.3.4.B)				

4. Supply Duct Sizing using Table 9.32.3.7.A & 9.32.3.7.B - For Systems not coupled with Forced Air			
Longest Total Duct Length from Grille to Outdoor Hood: _____ (69' max)			
Total # of fittings used: _____ (8 max)		Smooth	Flex
Min. Required Diameter for Outdoor Supply & Trunk Duct: _____		(see Table 9.32.3.7.A)	
Min. Required Diameter	1) Master Bedroom	_____	(see Table 9.32.3.7.B)
for Supply Branch Duct To:	2) Other Bedrooms	_____	(see Table 9.32.3.7.B)
	3) Storey with no bedrooms or living area	_____	(see Table 9.32.3.7.B)

5. Diagram	
-------------------	--

OBC Table 9.32.3.4.B - For Reference	Note:																							
<table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <tr> <th colspan="3">Principal Exhaust Fan Duct Size Table 9.32.3.4.B</th> </tr> <tr> <th rowspan="2">Number of Bedrooms in House or Dwelling Unit</th> <th colspan="2">Minimum Exhaust Duct Diameter</th> </tr> <tr> <th>Ducts Connected to Inlet and Outlet of Principal Exhaust Fan Smooth Duct</th> <th>Ducts Connected to One Side Only of Principal Exhaust Fan Smooth Duct</th> </tr> <tr> <td>1</td> <td>4" (100 mm)</td> <td>4" (100 mm)</td> </tr> <tr> <td>2</td> <td>5" (125 mm)</td> <td>5" (125 mm)</td> </tr> <tr> <td>3</td> <td>5" (125 mm)</td> <td>6" (150 mm)</td> </tr> <tr> <td>4</td> <td>6" (150 mm)</td> <td>6" (150 mm)</td> </tr> <tr> <td>5</td> <td>6" (150 mm)</td> <td>6" (150 mm)</td> </tr> </table>	Principal Exhaust Fan Duct Size Table 9.32.3.4.B			Number of Bedrooms in House or Dwelling Unit	Minimum Exhaust Duct Diameter		Ducts Connected to Inlet and Outlet of Principal Exhaust Fan Smooth Duct	Ducts Connected to One Side Only of Principal Exhaust Fan Smooth Duct	1	4" (100 mm)	4" (100 mm)	2	5" (125 mm)	5" (125 mm)	3	5" (125 mm)	6" (150 mm)	4	6" (150 mm)	6" (150 mm)	5	6" (150 mm)	6" (150 mm)	1) The duct shall always be at least as large as recommended by the manufacturer 2) If flexible ducting is used, it shall be increased by 1" (25 mm). 3) Where more than one exhaust inlet is connected to the principal exhaust fan (PEF), the branch ducts may be reduced by 1" (25 mm) 4) Where the supply and/or exhaust side of PEF is connected to the return side of the forced air heating, the duct shall be increased by 1" (25mm).
Principal Exhaust Fan Duct Size Table 9.32.3.4.B																								
Number of Bedrooms in House or Dwelling Unit	Minimum Exhaust Duct Diameter																							
	Ducts Connected to Inlet and Outlet of Principal Exhaust Fan Smooth Duct	Ducts Connected to One Side Only of Principal Exhaust Fan Smooth Duct																						
1	4" (100 mm)	4" (100 mm)																						
2	5" (125 mm)	5" (125 mm)																						
3	5" (125 mm)	6" (150 mm)																						
4	6" (150 mm)	6" (150 mm)																						
5	6" (150 mm)	6" (150 mm)																						

OBC Table 9.32.3.7.A and 9.32.3.7.B - For Reference																														
<table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <tr> <th colspan="2">Outdoor Air Supply and Main Trunk Duct Diameter Table 9.32.3.7.A</th> </tr> <tr> <th>Number of Bedrooms</th> <th>Trunk Duct Diameter</th> </tr> <tr> <td>1</td> <td>6" (150 mm)</td> </tr> <tr> <td>2</td> <td>6" (150 mm)</td> </tr> <tr> <td>3</td> <td>7" (175 mm)</td> </tr> <tr> <td>4</td> <td>7" (175 mm)</td> </tr> <tr> <td>5</td> <td>7" (175 mm)</td> </tr> </table>	Outdoor Air Supply and Main Trunk Duct Diameter Table 9.32.3.7.A		Number of Bedrooms	Trunk Duct Diameter	1	6" (150 mm)	2	6" (150 mm)	3	7" (175 mm)	4	7" (175 mm)	5	7" (175 mm)	<table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <tr> <th colspan="3">Minimum Branch Supply Duct Diameter Table 9.32.3.7.B</th> </tr> <tr> <th>Room, Space or Storey Served</th> <th>1 and 2 Bedroom Dwelling Units</th> <th>3,4 and 5 Bedroom Dwelling Units</th> </tr> <tr> <td>Master bedroom</td> <td>4" (100 mm)</td> <td>4" (100 mm)</td> </tr> <tr> <td>Other bedrooms</td> <td>3" (75 mm)</td> <td>3" (75 mm)</td> </tr> <tr> <td>A storey with no bedrooms or living area</td> <td>3" (75 mm)</td> <td>4" (100 mm)</td> </tr> </table>	Minimum Branch Supply Duct Diameter Table 9.32.3.7.B			Room, Space or Storey Served	1 and 2 Bedroom Dwelling Units	3,4 and 5 Bedroom Dwelling Units	Master bedroom	4" (100 mm)	4" (100 mm)	Other bedrooms	3" (75 mm)	3" (75 mm)	A storey with no bedrooms or living area	3" (75 mm)	4" (100 mm)
Outdoor Air Supply and Main Trunk Duct Diameter Table 9.32.3.7.A																														
Number of Bedrooms	Trunk Duct Diameter																													
1	6" (150 mm)																													
2	6" (150 mm)																													
3	7" (175 mm)																													
4	7" (175 mm)																													
5	7" (175 mm)																													
Minimum Branch Supply Duct Diameter Table 9.32.3.7.B																														
Room, Space or Storey Served	1 and 2 Bedroom Dwelling Units	3,4 and 5 Bedroom Dwelling Units																												
Master bedroom	4" (100 mm)	4" (100 mm)																												
Other bedrooms	3" (75 mm)	3" (75 mm)																												
A storey with no bedrooms or living area	3" (75 mm)	4" (100 mm)																												

Prepared By: _____	HRAI #: _____	Location: _____
Signature: _____	Date: _____	Official Use: _____

